

Karnataka State Souharda Federal Cooperative Ltd

TENDER DOCUMENT

PRE QUALIFICATION DETAILS AND PRICE TENDER

NAME OF WORK: Supply & Installation of 10 KVA DC ON-LINE UPS

LOCATION KSSFCL Belgaum Regional Office: #1119/B, Autonagar Industrial Area,
Near K.H.Patil Sabhabhavan Kanabargi, Belagavi- 590 015

ESTIMATED AMOUNT: 3,60,000/- INR

ISSUED TO: Smt/Sri _____.

DATE: _____.

I Tender Details	
1 Tender Number	KSSFCL/BC/BGM/BID/01/2022-23
2 Tender Title	Supply & Installation of 10KVA DC ON-LINE UPS
3 Location	KSSFCL Belgaum Regional Office: #1119/B, Autonagar Industrial Area, Near K.H.Patil Sabhabhavan Kanabargi, Belagavi- 590 015
4 Tender Category	WORKS
5 Type of Quotation	ITEM_WISE
6 Tender Evaluation Type	SINGLE_COVER
7 Department/Organization	KSSFCL/Building_Dept/Belagavi_Div
8 Denomination Type	RUPEES
9 Completion Period	15 Days

II General Conditions for Eligible Tenderers

- 1 Tenders from Joint ventures are not acceptable.
- 2 Any damage during the progress of work, the damage cost should be beared by the contractor.
- 3 All materials should be in good quality as per specification, quality certificate for the same should be obtained.
- 4 Contractor should made an agreement within 2 days of tender acceptance date and work should be carried out with in the 1 week time after agreement. If not tender will be cancelled at the contractors own risk and cost
- 5 EMD in favour of KSSFCL in the form of DD / FDR in the name of '**Karnataka state souharda federal cooperative Ltd**'
- 6 The work should be carried out in accordance with the standard specifications specified by the department. The defect liability period for all these works shall not be less than 1 year & the contrator shall have to give guarantee for 3 year maintainance.
- 7 If the rates quoted by the Contractor is lesser than the amount put to tender, the difference cost should be paid by the contractor, through DD / FDR / NSC
- 8 The Contractor should have experience in PVT/GOVT/SEMI_GOVT/PVT., and preference given to Kenionic Empaneled contractor
- 9 The Contractor should have experience and work done in Privet/GOVT/SEMI_GOVT,
- 10 The Contractor should enclose / attach all the necessary certificates duly self attested
- 11 To qualify for award of this contract each tenderer in his name should have in the last two years period (i.e., 2020-21 to 2021-22) Turnover Certificate obtained from Chartered Accountant and achieved in at least two financial years an average Annual Financial Turnover (in all classes of Supply & Installation of ON-LINE UPS) of Rs. 3 Lakhs

III SCHEDULE - B					
Name Of Work : Supply & Installation of 10KVA DC ON-LINE UPS					
Name Of The Contractor :					
GST-No:					
SI No	Description	Quantity	Unit	Contractor Part	
				Rate	Amount
1	2	3	4	7	8
1	10KVA DC ON-LINE UPS	NO	1		
	MAKE: AS				
	DOUBLE CONVERSION				
	DOUBLE CONVERSION, DIGITAL DISPLAY				
	IGBT TECHNOLOGY & WITH ISOLATION				
	3 PHASE INPUT & 3PHASE OUTPUT				
2	BATTERY FOR 4 HR.BACK UP 120 AH AM RON QUANTA	NO	16		
	WARRANTY - 3 YEARS,MAKE: EXIDE/QUANTA TYP:SMF CAPACITY: 150AH				
3	BATTERY RACK,INTER CONNECTING CABLES, THE LENGTH & REQUIRED BASIC ACCESSORIES LIKE CABLE, POWER POINTS AS REQUIRED FROM THE JOB PANEL BOARD TO UPS POINT AND INSTALLATION CHARGES		1		
	AMOUNT				
	GST 18%				
	GST 28%				
	Total Amount				
Contractor/ Proprietor					

I